



Clean Air Filter // Quality Tested. Performance Proven.

2203 HWY 59 Po Box 212 Defiance, IA 51527  
712 748 3642 cleanairfilter.com

**Filtration Efficiency Testing Report for:**

**CAF950R / FPS955**

8-Oct-2018

Test Number: 181008-1

Clean Air Filter  
2203 Hwy 59  
Defiance, Iowa 51527


CAF Staff

Ernest S. Moyer  
Michael R Schmitz  
Neil Schmitz

**TEST A - DIFFERENTIAL COUNT RESULTS (negative values removed)**

Outside OPC Serial# 3330-606  
Inside OPC Serial# 3330-604  
Test Started: 9:03  
Test Ended: 9:22


Test Number:



Particle Size Range	Mean Efficiency (%)	95% Confidence Interval	
		Minimum (%)	Maximum (%)
0.3-0.4µm	99.999	99.999	99.999

**TEST A - CUMULATIVE COUNT RESULTS (negative values removed)**

Outside OPC Serial# 3330-606  
Inside OPC Serial# 3330-604  
Test Started: 9:03  
Test Ended: 9:22



Particle Size Range	Mean Efficiency (%)	95% Confidence Interval	
		Minimum (%)	Maximum (%)
>0.30 µm	99.999	99.999	99.999
>0.40 µm	99.999	99.998	100.000